



SECTION 08625 [08 62 23]

TUBULAR DAYLIGHTING DEVICES

Display hidden notes to Specifier. (Don't know how? [Click Here](#))

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Tubular daylighting devices and accessories.

1.2 RELATED SECTIONS

- A. Section 06100 [06 10 00] - Wood Framing; Site built wood curbs and nailers.
- B. Section 07310 [07 31 00] - Roof Shingles and Shakes: Flashing of skylight base.
- C. Section 07320 [07 32 00] - Roof Tiles: Flashing of skylight base.
- D. Section 07510 [07 51 00] - Built-Up Bituminous Roofing: Flashing of skylight base.
- E. Section 07520 [07 52 00] - Modified Bituminous Membrane Roofing: Flashing of skylight base.
- F. Section 07530 [07 53 00] - Electrometric Membrane Roofing: Flashing of skylight base.
- G. Section 07540 [07 54 00] - Thermoplastic Membrane Roofing: Flashing of skylight base.
- H. Section 07600 [07 60 00] – Flashing and Sheet Metal: Metal curb flashings.
- I. Section 08620 [08 60 00] - Unit Skylights: Skylights without reflective tube.
- J. Section 08630 [08 63 00] - Metal Framed Skylights.
- K. Section 15810 [23 30 00] – HVAC Air Distribution: Fan vent duct and connections.
- L. Section 16570 [25 50 00] – Integrated Automation Facility Controls: Lighting controllers.
- M. Section 16150 [26 05 00] – Common Work Results Electrical: Power cable, power supply and electrical connections.
- N. Section 16500 [26 50 00] – Lighting Equipment and Controls: Control cable, dimming controls, light bulbs and lamps.

1.3 REFERENCES

- A. ASTM B 209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- B. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- C. ASTM A 463/A 463M - Standard Specification for Steel Sheet, Aluminum Coated, by the Hot Dip Process.
- D. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized), by the Hot Dip Process.
- E. ASTM A 792/A 792M – Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process.
- F. ASTM E 108 - Standard Test Methods for Fire Tests of Roof Coverings.
- G. ASTM E 283 - Test Method for Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen.
- H. ASTM E 308 - Standard Practice for Computing the Colors of Objects by Using the CIE System.
- I. ASTM E 330 - Structural Performance of Exterior Windows, Curtain Walls and Doors.
- J. ASTM E 547 - Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain walls by Cyclic Air Pressure Difference.
- K. ASTM E 1886 - Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.
- L. ASTM E 1996 - Standard Specification for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Windborne Debris in Hurricane.
- M. ASTM D 635 - Test Method for Rate of Burning and/or Extent of Time of Burning of Self-Supporting Plastics in a Horizontal Position.
- N. ASTM D 1929 - Test Method for Ignition Properties of Plastics.
- O. ASTM D 2843 – Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics.
- P. ASTM F 1642 – Standard Test Method for Glazing and Glazing Systems Subject to Airblast Loading.
- Q. ASTM F 2912 – Standard Specification for Glazing and Glazing Systems Subject to Airblast Loading.

- R. AAMA/WDMA/CSA 101/I.S.2/A440 - Standard/Specification for Windows, Doors, and Unit Skylights; 2011
- S. FM Standard 4431 - The Approval Standard for Skylights
- T. UL 2108 - Low Voltage Lighting Systems
- U. GSA-TS01-2003: Standard Test Method for Glazing and Window Systems Subject to Dynamic Overpressure Loadings
- V. Unified Facilities Criteria (UFC) 4-010-01, Change October 2013, DoD Minimum Antiterrorism Standards for Buildings,
- W. CSA C22.2 No. 250.0 – Luminaires.
- X. ICC-ES AC-16 - Acceptance Criteria for Plastic Skylights; 2008.
- Y. Florida Building Code TAS 201 – Impact Test Procedures.
- Z. Florida Building Code TAS 202 – Criteria for Testing Impact and Non Impact Resistant Building Envelope Components Using Uniform Static Air Pressure Loading.
- AA. Florida Building Code TAS 203 – Criteria for Testing Products Subject to Cyclic Wind Pressure Loading
- BB. IBC Section 1710 - Load Test Procedure for Wind Load Testing on Rooftop Daylight Collecting System - Structural Performance Testing - Devised by ATI PE); 2012
- CC. IBC Section 2606.7.2 – Installation – Diffuser Fall Out Test (Devised by PE); 2012
- DD. OSHA 29 CFR - 1910.23 (e)(8) (Guarding Requirements for Skylights); 1926 Subpart M (Fall Protection); 1926.501(b)(4)(i); 1926.501(i)(2); 1926.501(b)(4)(ii)
- EE. California State OSHA Fall Protection Code of Regulations, Title 8, Section 3212 (e)(1)

1.4 PERFORMANCE REQUIREMENTS

- A. Daylight Reflective Tubes: Spectralight Infinity with Cool Tube Technology combines ultra-high Visible Light reflectance with Ultra-low Infrared (IR) reflectance. Patented spectrally-selective optical surface yields an average total- and specular-reflectance greater than 99.5% percent for the Visible Light spectrum (400 nm to 700 nm) providing maximized visible light transmission and less than 25% reflectance for Infrared (IR) heat wavelengths (750 nm to 2500 nm) for minimized heat transmission, resulting in a spectrally-selective Total Solar Spectrum (250 nm to 2500 nm) reflectance less than 37 percent, as measured using a Perkin Elmer Lambda 1050 spectrophotometer with a Universal Reflectance Accessory. Color: a* and b* (defined by CIE L*a*b* color model) shall not exceed plus 2 or be less than minus 2 as determined in accordance to ASTM E 308.
- B. BRIGHTEN UP 290 DS (Suspended or Open Ceilings)
 - 1. AAMA/WDMA/CSA 101/IS2/A440, Class CW-PG70 size tested 14 inch (356 mm), Type TDDCC.

- a. Air Infiltration Test: Air infiltration will not exceed 0.30 cfm/sf aperture with a pressure delta of 1.57 psf across the tube when tested in accordance with ASTM E 283.
- b. Water Resistance Test:
 - 1) Passes water resistance; no uncontrolled water leakage with a pressure differential of 10.7 psf (512 Pa) or 15 percent of the design load (whichever is greater) and a water spray rate of 5 gallons/hour/sf for 24 minutes when tested in accordance with ICC-ES AC-16, ASTM E 547 and ASTM E 331.
- c. Uniform Load Test: All units tested with a safety factor of (3) for positive pressure and (2) for negative pressure, acting normal to plane of roof in accordance with ASTM E 330.
 - 1) No breakage, permanent damage to fasteners, hardware parts, or damage to make system inoperable or cause excessive permanent deflection of any section when tested at a Positive Load of 150 psf (7.18 kPa) or Negative Load of 60 psf (2.87 kPa) in accordance with ICC AC-16 Section A, or Negative Load of 70 psf (3.35 kPa) if tested per ICC AC-16 Section B.
- d. Hurricane Resistance:
 - 1) Meets Florida Building Code TAS, 201, TAS, 202 and TAS 203 for Impact and non-impact components.
 - 2) Meets ASTM E 1886 and ASTM E1996 for missile and cyclic pressure differential testing.
- e. Fire Testing:
 - 1) When used with the Dome Edge Protection Band, all domes meet fire rating requirements as described in the International Building Code.
 - 2) Self-Ignition Temperature - Greater than 650 degrees F per ASTM D-1929.
 - 3) Smoke Density: Rating no greater than 450 per ASTM Standard E 84 in way intended for use. Classification C.
 - 4) Rate of Burn and/or Extent: Maximum Burning Rate: 2.5 inches/min (62 mm/min) Classification CC-2 per ASTM D 635.
 - 5) Rate of Burn and/or Extent: Maximum Burn Extent: 1 inch (25 mm) Classification CC-1 per ASTM D 635.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Data sheets showing roof dome assembly, flashing base, reflective tubes, diffuser assembly, and accessories.
 - 4. Installation requirements.
- C. Shop Drawings. Submit shop drawings showing layout, profiles and product components, including rough opening and framing dimensions, anchorage, roof flashings and accessories.
- D. Electrical wiring diagrams and recommendations for power and control wiring.
- E. Verification Samples: As requested by Architect.

- F. Test Reports: Independent testing agency or evaluation service reports verifying compliance with specified performance requirements.
- G. LEED Submittals: Provide documentation of how the requirements of Credit will be met:
 - 1. List of Daylight Credits available for the products specified.
 - 2. Data on Energy Optimization Performance Credits for the products specified.
 - 3. Data on Perimeter and Non-Perimeter Controllability of Systems for use of Daylight Dimmer option with the products specified.
 - 4. Data on potential Innovation in Design Credits which may be available for the innovative use of the products specified.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Engaged in manufacture of tubular daylighting devices for minimum 20 years.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products in manufacturer's original containers, dry, undamaged, seals and labels intact.
- B. Store products in manufacturer's unopened packaging until ready for installation.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- A. Daylighting Device: Manufacturer's standard warranty for 10 years.
- B. Electrical Parts: Manufacturer's standard warranty for 5 years, unless otherwise indicated.
- C. LED Emitters, Drivers and Controls: Manufacturer's standard warranty for 3 years against failure.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Solatube International, Inc.; 2210 Oak Ridge Way, Vista, CA 92081. Tel. Toll Free: 888-765-2882. Tel: (760) 477-1120. Fax: (760) 597-4488. Email: commsales@solatube.com. Web: www.solatube.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 TUBULAR DAYLIGHTING DEVICES

- A. Tubular Daylighting Devices General: Transparent roof-mounted skylight dome and self-flashing curb, reflective tube, and ceiling level diffuser assembly, transferring sunlight to interior spaces; complying with ICC AC-16.
- B. Brighten Up Series: Solatube Model 290 DS: 14 Inch (350 mm) Daylighting System:
1. Model:
 - a. Solatube Model 290 DS used for daylighting systems with suspended or hard ceilings. AAMA Type TDDCC.
 2. Capture Zone:
 - a. Roof Dome Assembly: Transparent, UV and impact resistant dome with flashing base supporting dome and top of tube.
 - 1) Outer Dome Glazing: Type DA, 0.125 inch (3.25 mm) minimum thickness impact resistant injection molded acrylic classified as CC2 material; UV inhibiting (100 percent UV C, 100 percent UV B and 98.5 percent UV A), impact modified acrylic blend.
 - (a) Raybender 3000: Variable prism optic molded into outer dome to capture low angle sunlight and limit high angle sunlight.
 - 2) Shock Inner Dome Glazing: Type DAI, 0.115 inch (2.9 mm) minimum thickness classified as CC1 material. High impact resistant injection molded acrylic required for high velocity wind zones.
 - 3) Tube Ring: Attached to top of base section; 0.090 inch (2.3 mm) nominal thickness injection molded high impact acrylic; to prevent thermal bridging between base flashing and tubing and channel condensed moisture out of tubing.
 - 4) Dome Seal: Polyethylene foam seal, black, 0.13 inch (3.2 mm) thick by 14.62 (371 mm) diameter, 2 PCF polyethylene foam.
 - 5) LightTracker Reflector, made of aluminum sheet, thickness 0.015 inch (0.4 mm) with Spectralight Infinity. Positioned in the dome to capture low angle sunlight.
 - b. Dome Options:
 - 1) Dome Edge Protection Band: Type PB, for fire rated Class A, B or C roof applications. Aluminized steel nominal thickness of 0.028 inches (0.7 mm).
 - c. Flashings:
 - 1) Roof Flashing Base:
 - (a) One Piece: One piece, seamless, leak-proof flashing functioning as base support for dome and top of tube. Sheet steel, corrosion resistant conforming to ASTM A 653/A 653M or ASTM A 463/A 463M or ASTM A792/A 792M, 0.028 inch (0.7 mm) plus or minus .006 inch (.015 mm) thick.
 - (1) Base Flat: Flat Type F4, no pitch 4 inches (102 mm) high.
 - (2) Base Flat: Flat Type F6, no pitch 6 inches (152 mm) high.
 - (3) Base Pitched: Pitched Type FP, 22.5 degrees slope from horizontal, 4 inches (102 mm) high.
 - (4) Base Style: Type FC, Curb Cap, with inside dimensions of 27 inches by 27 inches (685 mm by

685 mm) to cover curb as specified in Section 07600.

- (5) Tile Roof No Pitch: No Pitch Type FT, 4 inches (102 mm) high. Tile Roof Counter-Flashing: corrugated aluminum 1100-0, 0.020 inch (.508 mm).
- (6) Tile Roof Pitched: Pitched Type FPT, 22.5 degrees slope from horizontal, 4 inches (102 mm) high. Tile Roof Counter-Flashing: corrugated aluminum 1100-0, 0.020 inch (.508 mm).

2) Flashing Options:

- (a) Flashing Insulator: Type FI thermal isolation material for use under flashing.
- (b) Metal Roof Flashing Kit: Type MR, includes Butyl tape, flashing screws, speed nuts, corner washers and polyurethane sealant.
- (c) Curb Cap Insulation: Type CCI, nominal 1 inch thick thermal isolation pad to reduce thermal conduction between curb-cap and tubing and thermal convection between room air and curb-cap. Rated R-6 ($^{\circ}\text{F}\cdot\text{ft}^2\cdot\text{hr}/\text{Btu}$) Insulation is Polyisocyanurate foam utilizing CFC, HCFC, & HFC free blowing agent. Type-1 Class-1 per ASTM C 1289; Passes UL 1715 (15-minute thermal barrier per IBC 2603.4); Attic ventilation may be required per IBC 1203.2($\text{OF}\cdot\text{ft}^2\cdot\text{hr}/\text{Btu}$)
- (d) Roof Flashing Turret Extensions: Provide manufacturer's standard extensions for applications requiring:
 - (1) Type T02 Additional lengths of 2 inches (50 mm) extension.
 - (2) Type T04 Additional lengths of 4 inches (100 mm) extension.
 - (3) Type T012 Additional lengths of 12 inches (300 mm) extension.
 - (4) Type T024 Additional lengths of 24 inches (600 mm) extension.
 - (5) Type T036 Additional lengths of 36 inches (900 mm) extension.
 - (6) Type T048 Additional lengths of 48 inches (1200 mm) extension.

3. Transfer Zone:

a. Extension Tubes: Aluminum sheet, thickness 0.015 inch (0.4 mm).

1) Reflective Tubes:

- (a) Reflective Extension Tube: Type EXX with total length of run as indicated on the Drawings.
- (b) Interior Finish: Spectralight Infinity with Cool Tube Technology combining ultra-high Visible Light reflectance with Ultra-low Infrared (IR) reflectance.
- (c) Color: a^* and b^* (defined by CIE $L^*a^*b^*$ color model) shall not exceed plus 2 or be less than minus 2 as determined in accordance to ASTM E 308.

2) Tube Options

- (a) Extension Tube Angle Adapter: Provide manufacturer's standard adapters for applications requiring:
 - (1) Type A1 one 0 to 90 degree extension tube angle adapter.

- (2) Type A2 two 0 to 90 degree extension tube angle adapters.
 - (b) Severe Climate Glazing: Type SCG, PET GAG plastic glazing to minimize potential for condensation and heat loss. Nominal thickness is 0.039 inches (0.99 mm).
 - (c) Wire Suspension Kit: Type E, use the wire suspension kit when additional bracing to the structure is required.
 - (d) Thermal Insulation Panel: Type TIP, high-performance dual-glazed, tube insulation system.
- 4. Delivery Zone:
 - a. Ceiling Ring: Injection molded impact resistant acrylic. Nominal thickness is 0.110 inches (2.8 mm).
 - b. Ceiling Ring Seal: Polyethylene foam seal, white, 0.25 inch (6.4 mm) wide by 0.19 inch (4.8 mm) high, 2 PCF polyethylene foam with low-tack pressure sensitive adhesive.
 - c. Upper glazing: PET GAG plastic with EPDM low density sponge seal to minimize condensation and bug, dirt, and air infiltration per ASTM E283. The nominal thickness is 0.039 inches (0.99 mm).
 - 1) Natural Effect Lens: Type LN.
 - 2) Softening Effect Lens: Type LS.
 - 3) Warm Effect Lens: Type LW.
 - 4) Warm Softening Effect Lens: Type LWS.
 - d. Round Diffusers/Decorative Fixtures: Dual Glazed Diffuser Assembly.
 - 1) Lower glazing with integral injection molded acrylic Dress Ring classified as CC2 material. Nominal thickness is 0.110 inches (2.8 mm)
 - (a) Classic Vusion Diffuser: Type L4, molded acrylic plastic classified as CC2 material (nominal thickness 0.090 inches (2.29 mm) with injection molded acrylic Diffuser Trim Ring.
 - (b) Classic OptiView (Fresnel Lens) Diffuser: Type L1, molded polycarbonate plastic classified as CC1 material, nominal thickness 0.022 inches (0.61 mm) with injection molded acrylic Diffuser Trim Ring.
 - (c) JustFrost Decorative Fixture: Type L9, frosted acrylic plastic lens classified as CC2 material (nominal thickness is 0.16 inches (4 mm)), and decorative metal fasteners.
 - (d) TierDrop Decorative Fixture: Type L10, three layers of frosted acrylic plastic lens classified as CC2 material (nominal thickness is 0.16 inches (4 mm)). Bottom layer is continuous with two stepped full-tempered glass rings on top and decorative metal fasteners.
 - (e) OptiView Decorative Fixture: Type L11, molded polycarbonate plastic Fresnel Lens classified as CC1 material (nominal thickness is 0.022 inches (0.61 mm)) with full-tempered frosted glass bezel (nominal thickness is 0.16 inches (4 mm)), and decorative metal fasteners.
 - (f) VividShade Decorative Fixture: Type L12, frosted acrylic plastic lens classified as CC2 material (nominal thickness is 0.16 inches (4 mm)), integral flame retardant linen shade with translucent frosted PVC inner liner, nominal thickness 0.16 inches (0.4mm); decorative zinc plated steel (concealed) and stainless steel (exposed) fasteners.

- 2) Lower decorative glazing with integral 2-piece aluminum/zinc alloy coated steel Fixture Mounting Ring, 23 gauge; nominal thickness 0.031 inches (0.787 mm):
 - (a) AuroraGlo Decorative Fixture: Type L16, Glass Bowl acid etched lens, with two-tone black/bronze painted decorative metal trim ring. Low profile.
 - (b) AuroraGlo Decorative Fixture: Type L15, Glass Bowl acid etched lens, with white painted decorative metal trim ring. Low profile.
- e. Square Diffuser Assemblies for Tubes Penetrating Ceilings: Ceiling mounted box transitioning from round tube to square ceiling assembly, supporting light transmitting surface at bottom termination of tube 14 inches by 14 inches (356 mm by 356 mm) square diffuser opening.
 - 1) Square JustFrost Decorative Fixture: Type L9, frosted acrylic plastic lens classified as a CC2 material lens (nominal thickness is 0.16 inches (4 mm)), and decorative metal fasteners.
 - 2) Square OptiView Decorative Fixture: Type L11, molded polycarbonate plastic Fresnel Lens classified as CC1 material (nominal thickness is 0.022 inches (0.61 mm)) with white metal bezel (nominal thickness is 0.16 inches (4 mm)), and decorative metal fasteners.
- f. Delivery Zone Options:
 - 1) Local Dimmer Control utilizing a butterfly baffle design of Spectralight Infinity reflective material to minimize shadowing when in use: Provided with dimmer switch and cable.
 - (a) Daylight Dimmer: Type D, electro-mechanically actuated daylight valve; for universal input voltages ranging between 90 and 277 V at 50 or 60 Hz; maximum current draw of 50 ma per unit; controlled by low voltage, series Type T02. Provided with dimmer switch and cable.
 - 2) Lighting Fixture: Bracket mounted inside system just above diffuser; UL and CSA Listed.
 - (a) Universal: Type INC, for two 23 W maximum CFL, maximum total length 4-3/4 inch, ceramic screw-in lamp holder, medium base, two lamps.
 - (b) Compact Fluorescent: Type CFL, dedicated compact fluorescent fixture, for one 26 W, 4-pin lamp.
 - (c) Electrical Requirements: 110 V, 15 amp GFCI circuit for damp and wet conditions.
5. Accessories
 - a. Switch: Type SW, Manufacturer-specific low voltage DC DP/DT switch (white) required to operate Daylight Dimmer. Note: A maximum of 10 units can be connected to one switch. For use with Daylight Dimmer, Type D, only.
 - b. Cable: Type CA, Two conductor, 22 gauge, low voltage cable (500 ft.) for multiple unit DC connections. For use with Daylight Dimmer, Type D, only when aggregate circuit runs do not exceed 200 feet (60.96 m).

2.3 ACCESSORIES

- A. Fasteners: Same material as metals being fastened, non-magnetic steel, non-corrosive metal of type recommended by manufacturer, or injection molded nylon.

- B. Suspension Wire: Steel, annealed, galvanized finish, size and type for application and ceiling system requirement.
- C. Sealant: Polyurethane or copolymer based elastomeric sealant as provided or recommended by manufacturer.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. Examine openings, substrates, structural support, anchorage, and conditions for compliance with requirements for installation tolerances and other conditions.
- C. If substrate and rough opening preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Coordinate requirements for power supply, conduit and wiring.
- C. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's printed instructions.
- B. Coordinate installation with substrates, air and vapor retarders, roof insulation, roofing membrane, and flashing to ensure that each element of the Work performs properly and that finished installation is weather tight.
 - 1. Install flashing to produce weatherproof seal with curb and overlap with roofing system termination at top of curb.
 - 2. Provide thermal isolation when components penetrate or disrupt building insulation. Pack fibrous insulation in rough opening to maintain continuity of thermal barriers.
 - 3. Coordinate attachment and seal of perimeter air and vapor barrier material.
- C. Where metal surfaces of tubular unit skylights will contact incompatible metal or corrosive substrates, including preservative-treated wood, provide permanent separation as recommended by manufacturer
- D. Align device free of warp or twist, maintain dimensional tolerances.
- E. After installation of first unit, field test to determine adequacy of installation. Conduct water test in presence of Owner, Architect, or Contractor, or their designated representative. Correct if needed before proceeding with installation of subsequent units.

- F. Inspect installation to verify secure and proper mounting. Test each fixture to verify operation, control functions, and performance. Correct deficiencies.

3.4 CLEANING

- A. Clean exposed surfaces according to manufacturer's written instructions. Touch up damaged metal coatings and finishes. Remove excess sealants, glazing materials, dirt, and other substances.

3.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION